

**Customer:** Labella Associates (1126)  
**Address:** 300 State Street  
Rochester, NY 14614-1098

**Order #:** 393148


**Received**

**Attn:**  
**Project:** 2020 Lead In Drinking Water

**Number:** 2203031

**PO Number:**





Analysis Report

# Schneider Laboratories Global, Inc

**Customer:** Labella Associates (1126)  
**Address:** 300 State Street  
Rochester, NY 14614-1098

**Order #:** 393148

**Matrix** Drinking Water  
**Received** 11/06/20  
**Reported** 11/09/20

**Attn:**  
**Project:** 2020 Lead In Drinking Water  
**Location:** 8685 Erie Rd Angola, NY 14006  
**Number:** 2203031

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
393148-012	3016-1F-11	111 Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/07/20	HI
393148-013	3018-1F-12	Girls Lav Far Left					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	28.1	5.00	µg/L	11/07/20	HI
393148-014	3019-1F-13	Girls Lav Far Right					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	11.5	5.00	µg/L	11/07/20	HI
393148-015	3020-1F-14	Girls Lav Left					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	55.1	10.0	µg/L	11/07/20	HI
393148-016	3021-1F-15	Girls Lav Right					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	24.2	5.00	µg/L	11/07/20	HI
393148-017	3022-1F-16	201B Lav					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	20.2	5.00	µg/L	11/07/20	HI
393148-018	3023-1F-17	203 Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	30.7	5.00	µg/L	11/07/20	HI
393148-019	3024-1F-18	207 Sink Left					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	46.8	10.0	µg/L	11/07/20	HI
393148-020	3025-1F-19	207 Sink Center					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	14.5	5.00	µg/L	11/07/20	HI
393148-021	3026-1F-20	207 Sink Right					
<b>Metals Analysis</b>							
Lead					µg/L	11/07/20	HI



**Address:** 300 State Street

<b>Order #:</b> 393148
------------------------

**Attn:**

